MAHARASHTRA STATE PUBLIC HEALTH SERVICES.
DISTRICT PUBLIC HEALTH LABORATORY, NANDED.
REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER.
jsodphlnanded@gmail.com. Ph - (02462)232554

Name & Address of Sender :-	Principal,Shantiniketan Public School,Malegaon Tq.Ardhapur Dist.Nanded
Sender's Letter No.& Date :-	---------- Date- 21/04/2026
Laboratory Reference No. :-	2303
Date of Collection :- Date ofArrival at Laboratory . :- Date of Commencing Examination :- .	21-04-2026 21-04-2026 21-04-2026

Sr. No.	Particular of Water Samples	Result of Analysis – Most Probable Number per 100ml.			
		Coliforms	Thermotolerant Coliforms	E.coli	Fit/Unfit
1	R.O.Water Sample	0	---	---	Fit

The analysis report pertains to the sample as submitted by the party.

Remark:- Above water samples if unfit bacteriologically for drinking purposes. However it / they can be used, only after proper treatment, chlorination and retesting bacteriologically to ascertain its/ their fitness for drinking purposes.

Govt. Reciept No 2974938 Dt.- 21 /04/2026. Rs -340/-

Report outward No.-: 894/2026 Date.-: 24/04/2026

Junior Scientific Officer.
District Public Health Laboratory
NANDED.